

QSC*i* Quality Systems Certification Institute

Quality Systems Certification Institute, hereby declares testing has been completed and reports have been generated for:

Certificate No.: 08-362MK6A

Applicant: Reliability Power Systems
Level-17, 40 Mount Street, North Sydney 2060, Australia

Manufacturer: Reliability Power Systems
Level-17, 40 Mount Street, North Sydney 2060, Australia

Product: UPS

Model: REL2900II

Rating:
AC Input: 3/N/PE, 380/220VAC, 50/60Hz, PF>0.99
UPS Output: 3/N/PE, 380/220VAC, 50/60Hz, 10kVA – 120kVA
DC Input: 384VDC, 26A – 313A

And, in accordance with the following applicable directives:


2006/95/EC Low Voltage Directive

That this product has been assessed against the following applicable standards;

EN 62040-1: 2008

Therefore, Quality Systems Certification Institute, hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules.

For QSCI



Jeremy Birch, President
Quality Systems Certification Institute (QSCI)
Southfield House, 2 Southfield Road
Westbury on Trym, Bristol, BS9 3BH, UK
www.qsci.org

