

# QSC*i* Quality Systems Certification Institute

## CE Certificate of Conformity

Quality Systems Certification Institute, hereby declares testing has been completed and reports have been generated for:

**Certificate No.:** 08-69255S0

**Applicant:** Reliability Power Systems  
32 Duekett St., Beaudesert QLD 4285, Australia

**Manufacturer:** Reliability Power Systems  
32 Duekett St., Beaudesert QLD 4285, Australia

**Product:** UPS

**Model:** REL4700

**Rating:** AC Input: 3/N/PE, 380/220VAC, 50/60Hz, PF>0.99  
UPS Output: 3/N/PE, 380/220VAC, 50/60Hz, 160kVA – 600kVA  
DC Input: 600VDC, 270A – 1020A

And, in accordance with the following applicable directives:


2006/95/EC Low Voltage Directive

That this product has been assessed against the following applicable standards;

EN 62040-1: 2008

Therefore, Quality Systems Certification Institute, hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules.

For QSCI



Jeremy Birch, President  
Quality Systems Certification Institute (QSCI)  
Southfield House, 2 Southfield Road  
Westbury on Trym, Bristol, BS9 3BH, UK

