

QSC*i* Quality Systems Certification Institute

Quality Systems Certification Institute, hereby declares testing has been completed and reports have been generated for:

Certificate No.: 21-27D86L7

Applicant: Reliability Power Systems
Level-17, 40 Mount Street, North Sydney, 2060, Australia

Manufacturer: Reliability Power Systems
Level-17, 40 Mount Street, North Sydney, 2060, Australia

Product: UPS

Model: REL2700

Rating: **AC Input:** 1/N/PE, 220VAC, 50/60Hz, PF>0.99
UPS Output: 1/N/PE, 220VAC, 50/60Hz, 1kVA – 20kVA
DC Input: 48VDC – 240VDC, 16A – 67A

And, in accordance with the following applicable directives:


2006/95/EC Low Voltage Directive

That this product has been assessed against the following applicable standards;

EN 62040-1: 2008

Therefore, Quality Systems Certification Institute, hereby acknowledges that the applicant may issue a **DECLARATION of CONFORMITY** and apply the CE marking in accordance with European Union Rules.

For QSCI



Jeremy Birch, President
Quality Systems Certification Institute (QSCI)
Southfield House, 2 Southfield Road
Westbury on Trym, Bristol, BS9 3BH, UK
www.qsci.org

